

NOTES:

- (1) SUBMITTALS MUST BE APPROVED BY THE ACSA BEFORE THE VAULT IS ORDERED.
- (2) WHEN POSSIBLE, PIPE TO ATMOSPHERE-4" SCH 40 PVC PIPE. CHECK WITH ACSA ABOUT DRAIN PIPE LOCATION AND CONFIGURATION BEFORE CORING OUT THE BLOCKOUT. NOTIFY ACSA ENGINEERING DEPT. IN AREAS OF HIGH WATER TABLE.

AUGUSTA COUNTY SERVICE AUTHORITY VERONA, VIRGINIA

SCALE: NTS

DRAWN BY: ACSA

DATE: AUGUST 2020

REVISED: APRIL 2021

TYPICAL VAULT FOR FIRE LINE METERS

DRAWING NUMBER: W-10A

PAGE: 1 OF 1