



NOTES:

1. COORDINATE THE SHUTDOWN OF THE EXISTING WATERLINE WITH ACSA IN ACCORDANCE WITH DESIGN STANDARDS.
2. REPAIR CLAMP IS TO BE IN ACCORDANCE WITH THE APPROVED PRODUCTS LIST.
3. WATER METER, METER BOX, METER BOX FRAME & COVER ARE TO BE RETURNED TO THE ACSA.
4. THE CONTRACTOR IS RESPONSIBLE FOR DEWATERING TRENCH PRIOR TO BACKFILLING.

**AUGUSTA COUNTY SERVICE AUTHORITY  
VERONA, VIRGINIA**

SCALE: NTS

DRAWN BY: ACSA

DATE: APR. 2021

REVISED:

**TYPICAL WATER SERVICE  
LATERAL ABANDONMENT**

DRAWING NUMBER: W-12

PAGE: 1 OF 1