



IF PEX<sub>a</sub> PIPE IS INSTALLED, TAPE 10 GAUGE  
THHN SOLID COPPER TRACER WIRE TO PIPE.  
INSULATION IS TO BE STRIPPED AND THE  
WIRE IS TO BE WRAPPED TO THE CORP.  
STOP, THEN WRAPPED WITH ELECTRICAL TAPE.

METER SIZE	LATERAL SIZE
5/8"	3/4" (1" IF CROSSING ROADWAY)
5/8" DOUBLE CONN.	1"
3/4"	1"
1"	1"

**AUGUSTA COUNTY SERVICE AUTHORITY  
VERONA, VIRGINIA**

SCALE: NTS

DRAWN BY: ACSA

DATE: FEB. 1996

REVISED: NOV. 2020

**TYPICAL WATER SERVICE LATERAL  
INSTALLATION 5/8" - 1" METERS**

DRAWING NUMBER: W-6

PAGE: 1 OF 1