

Bid Addendum

Addendum No. 1 for Augusta Water Middle River WWTP Aerobic Digester Blowers ITB No. 2315, Wiley|Wilson Comm. No. 230117.00.

Addendum Date: March 1, 2024
To: All Bidding Manufacturers
From: Wiley|Wilson
Lynchburg, VA

This Addendum contains 1 page and listed attachments and forms a part of the bidding documents and modifies the Invitation to Bid and Specifications dated February 7, 2024, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject bidder to disqualification.

QUESTIONS FROM BIDDERS

Question 1: If a named supplier or local distributor would like to submit bids for two separate blower technologies should the bids be submitted separately and noted accordingly?

Response: Yes; Separate bids are required.

Question 2: Should the manufacturer list the total input kW including the all package and control losses for the LCEC value? Or is blower block shaft power only being used for the LCEC calculation? For the LCEC calculation, should the manufacturer provide the aforementioned performance value at the design maximum pressure of 14.0psig or the normal operating pressure of 10.2psig?

Response: Provide the total input kW, including all package and control losses for the Life Cycle Electrical Cost (LCEC). These calculations should be performed using the design normal operating discharge pressure as specified.

End of Addendum No. 1

Wiley|Wilson



Aaron Tice, P.E.