

MT. SIDNEY WWTP LOCAL LIMITS (mg/L)	
Pollutant	Current Limit
BOD	250
Oil and Grease	100
pH (Standard Units)	5.0 – 11.0
TSS	250
Arsenic	1.68
Cadmium	0.25
Chromium	0.78
Copper	0.69
Cyanide	0.66
Lead	0.30
Mercury	0.0024
Nickel	14.80
Silver	1.97
Zinc	0.69

Effective Date: 7/13/2020